



ULTRASONIC REPORT

CLIENT INFO

CUSTOMER / CLIENT:	OTG	CLIENT JOB NO.:	1222	REPORT NO. :	UFO-221114-11
CONTRACTOR:		CLIENT CODING:	PO# 0605	PAGE:	1 OF 2
PROJECT:	UT SEPARATOR A0483264, SN 7809-03, CRN P7312.2			DATE:	14-Nov-22
LOCATION / LSD:	QUEENS IND PARK SHOP			TECHNICIAN:	FRANK ORELLANA
CODE / CLIENT SPEC:	ASME VIII Div. 1 / ASME V Art. 5	APPROVER:	MATT CAMPBELL	ASSISTANT:	NA

METHOD

ECHO PROCEDURE:	RCSS-NDT-UT-006 Rev 01 - Ultrasonic Thickness Measurement Technique - ASME V and ASME SE-797				
MANUFACTURER / MODEL:	GE DMS/USM Go	SERIAL NO.:	GOPLS20120006	LAST CALIBRATION DATE:	JAN 6/2022
MATERIAL TYPE:	CS	SURFACE CONDITION:	Painted	MATERIAL THICKNESS RANGE:	0.100" - 1.200"
SURFACE(S) INSPECTED FROM:	Outside Surface	CALIBRATION BLOCK:	1.000" STEP	*Daily Performance Calibration Completed as per T-462.1	
REFERENCE REFLECTOR:	Backwall	TYPE:		DEPTH:	0.200" - 1.000"
		SIZE:		RESPONSE FSH (%):	80%

TRANSDUCER:	ANGLE (°)	MODE	FREQ (MHz)	DIA (")	MFG	SN	RANGE	REF DB	SCAN DB	CABLE LEN. (")	COUPLANT
1	0	0°	5.00MHz	0.25"	Stresstel	20C0075T	50mm	51	57	36	UT-X
2											
3											
4											

EXAMINATION & TEST RESULTS

An ultrasonic thickness survey was performed on the above listed item, low and averages were recorded at time of inspection as requested by the client. View following page for locations and below for readings.

Band	Low	Avg	Nom	Location	Band	Low	Avg	Nom	Location
00	0.952	0.993	0.937	Head	55	0.329	0.346	0.343	Nozzle
05	0.998	1.009	1.000	Shell	60	0.338	0.364	0.343	Nozzle
10	0.993	1.014	1.000	Shell	65	0.323	0.350	0.343	Nozzle
15	0.995	1.013	1.000	Shell	70	0.848	0.860	0.600	Nozzle
20	0.862	0.978	0.937	Head	75	0.841	0.867	0.600	Nozzle
30	0.326	0.353	0.343	Nozzle	80	0.341	0.367	0.343	Nozzle
35	1.036	1.052	0.674	Nozzle	85	0.321	0.348	0.343	Nozzle
40	0.326	0.344	0.343	Nozzle	90	0.325	0.345	0.343	Nozzle
45	0.331	0.343	0.343	Nozzle	95	0.833	0.860	0.600	Nozzle
50	0.819	0.841	0.600	Nozzle	96	1.024	1.034	0.674	Nozzle
					97	0.809	0.822	0.600	Nozzle

*no access to band 25 due to cat "c" weld
 *pit found on bottom head and corrosion noted around head drain nozzle (band 20).

*readings in inches
 *nozzle nominals assumed

QUANTITIES

REGULAR TIME:	FILM:	
OVERTIME:	CONSUMABLES:	VIEW
SHIFT PREMIUM:	EQUIPMENT:	FFO-221114-1
KILOMETERS:	EXPENSES:	
SUBSISTENCE:	MISCELLANEOUS:	

FRANCISCO ORELLANA
 CGSB # 12307 UTII /MTII
 SNT-TC-1A UTII /MTII

CLIENT APPROVAL:



ULTRASONIC REPORT

CLIENT INFO

CUSTOMER / CLIENT: OTG

REPORT NO.: UFO-221114-11

PAGE: 2 OF 2

EXAMINATION & TEST RESULTS

DATE: Nov 14/22				TECHNICIAN: FO				ASSISTANT:			
Client: OTG				LSD				Item Band Location			
Equipment: Separator				RT: RT-1				Serial # / Manufacturer: 7809-03 NATCO			
CRN: P7312.2		A#: 483264		#		Year Built: 2002		Material: C C C/S			
DWG: 11		Survey		Plant or Field (Circle)		PSIG / KPA: 1440		F / C: 130		CA: 0.125"	
OUTSIDE Diameter: 2' 2' 2.375" 4.5" 3.5"				Type: 1 10 5 5 5				Comment: / / / / /			
Nominal Thickness: 0.937" 1.00" 0.343" 0.674" 0.600"											

Bottom head 40% scanned
Band 25 unable to scan due to kat "c" weld.

COMMENTS

- 1) Cryogenic Service
- 2) Insulated
- 3) No Name Plate
- 4) Name Plate Illegible
- 5) No Access
- 6) Too Hot
- 7) Rough Surface
- 8) O.D. Pitting
- 9) I.D. Pitting
- 10) Pipe / Plate (Circle One)

Piping Types

1. 90° Nozzle	6. 360° Circ Pipe
2. 90° Pipe	7. Tee Nozzle
3. 45° Nozzle	8. Tee Pipe
4. 45° Pipe	9. Straight Nozzle
5. 360° Circ Nozzle	10. Straight Pipe

Head Types

1 ellipsoidal	5 toriconical
2 torispherical	6 flat
3 spherical	7 hemispherical
4 conical	

Common Materials

A 53-B	C 516-70
B 106-B	D 234-WPB

Ensure all information is recorded for ve boots, when applicable.

SUNSET PRINTING (20