

FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
(Alternative Form for Single Chamber, Completely Shop or Field Fabricated Vessels Only)
As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division 1

								···		
1. Manufactured and certified by Opsco Energy Industries Ltd., 285175 kleysen way, Rocky View, AB. T1X 0K1										
(Name and address of Manufacturer)  2. Manufactured for HUSKY OIL OPERATION Ltd. BOX 4490, stn D, Calgary, AB. T2F 3G7										
(Name and address of Purchaser) 3. Location of installation Pocketknife Debolt LSD: a-081-H/94-G-6										
					8462.21	(Name and ad	dress) 33-01-001 Rev.1			2009
(Horizontal or vertical, tank) (Manufacturer's serial number) (CRN) (Drawing number) (National Board number) (Year built)										
5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEI CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 2007 ED.										
to 08 Add.										
6. Shell SA-516-70N 2.25" 0.125"						(Code Case no	4'-6" 14'-0"			
(Material spec. number, grade) (Nominal thickness) (Corr. allow.) (Inner diameter) [Length (over Type 1 FULL 100% 1150 F 2.25 hr Type 1 FULL 100% 2										
ILONG, CARREU, GR., SIGE, IAO, CORPER, J. (SICCO) (CORP. (COR), (COR), (COR), (ED.), (FILE, IN) (SIGE), (WEGEG, GIU., SIGE, IAO, DOLL) IV. (SIGE), (SICCO) (COR), (										
8. Heads: (a) Material SA-516-70N (Spec. no., grade) (b) Material SA-516-70N (Spec. no., grade)										
Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius			Conical Apex And		Flat Diameter		le to Pressure vex or Concave)
		0.125"	T CACALO	74300	Ratio 2:1	1 Apex Air	Jic Tabus	Dienticies	<u></u>	CAVE
	2.125"	0.125"			2:1				CON	CAVE
If removable, bolts used (describe other fastenings)										
9. MAWP 1350 PSI N/A at max. temp. (Material spec. number, grade, size, number) N/A										
(Internal) (External) (Internal) (External)										
Min. design metal temp20 F at 1350 PSI Hydro test pressure 2025 PSI  10. Nozzles, inspection, and safety valve openings:										
Purpose		Diameter				Nominal	Reinforcement	How		
(intet, Outlet, Drain)	Number 3	or Size	Туре	L600 SA	Vaterial 1000	Thickness 2.06"	Material Integral	Attache Fig. UW-1		Location
GAS INLET/OUTLET/WATER OUT. HC-OUTLET	1 1	4"		L600 SA		1.62"	Integral Integral			
FUTURE LC	+ 1	2"	RFLWN/CL600 S			0.66"	Integral		Fig. UW-16.1(c) SHELL Fig. UW-16.1(c) SHELL	
BR.CONN./PSV/FUTURE BR./TI/PI	6	2"	RFWN/CL600 S/				Integral	Fig. UW-16.1(c) SHELL		
FUTURE BRJBRJDRAIN/GAS PURC		2"	RFWN/CL600 S						6.1(c) S	
MANWAY	1	20"	RFV1/CL600 SA			3.88" Integral		Fig. UW-16.1(c)		
									$\dashv$	
	-		<del></del>						-+	
	<del> </del>	<u> </u>	<del> </del>	-						
NI/A	N/A N/A			Saddles		W	. Welded to Shell			
11. Supports: Skirt N/A (Yes or no) (Number) Lugs N/A Legs N/A (Number) Other Saddles Attached Welded to Shell (Where and how)										
12. Damada: Manufacturade Datial Data Danode remodulidantified and cionad by Commissioned Inspectors have been furnished for the following										
items of the report: VOLUME: 251Cu.ft (7.13 Cu.M) PSV Installed on N6 CONSTRUCTION DWG. NO: V-02-0133-01-001 Rev.1  (Name of part lism number, Manufacturer's name and Identifying stamp)										
hells and Heads Impact req'd as per UCS-66(a), and Production Impact test per UCS-67(a). Matt. Impact reqd. on item 101.102&103 All Other Matt. exempt per UG-20(f)(1-5)										
STUDS: SA-193-B7M & NUTS: SA-194-2HM										
OEDTIFICATE OF CHONGIFUD COMBINADO										
CERTIFICATE OF SHOP/FIELD COMPLIANCE										
We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME BOILER AND PRESSURE VESSEL CODE, Section Vill, Division 1. "U" Certificate of Authorization Number 21,356 expires JULY 21, 2010										
Date April 14, 2009 Co. name Opsco Energy Industries Ltd Signed Hossu										
(Manufacturer) (Representative)										
CERTIFICATE OF SHOP/FIELD INSPECTION  Vessel constructed by Opsco Energy Industries Ltd at CALGARY, ABERTA, CANADA										
1, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of										
ALBERTA and employed by ABSA have inspected the component described in this Manufacturer's Data Report on APR 17 2009 and state that,										
to the best of my knowle						sure vessel				
VESSEL CODE, Section										
implied, concerning the	•					•				
shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.  AB#270										
Date AFN 1 / ZUUSigned Commissions HST2+0  [National Board Und. endorsements). State, Province, and number]										

